

California Department of Public Health Product WorkSheet

Manufacturing Company Information  
 Pentair Residential Filtration, LLC  
 5730 N. Glen Park Road  
 Milwaukee, Wisconsin 53209  
 Phone: (262)-238-4400  
 Website: www.pentairaqua.com

Product Brand: EverPure  
 Product Model: PBS-400  
 CDPH registration # 13-2213  
 Replacement Cartridge PBS-400

Operating Parameters	SI Units	Metric Units
System Capacity	3000 gallons	11,355 Liters
Flow Rate	2.2 gpm	8.32 lpm
Pressure	10-125 psi	0.7 - 8.7 Kg/cm <sup>2</sup>
Temperature	35-100°F	1.6-37.8°C

EverPure PBS-400 Performance Data Sheet

Contaminant Reduction Claims	Challenge Concentration	Maximum Permissible Product Water Concentration	Reduction Requirements	Reduction Average
Cyst	Minimum 50,000/mL		≥ 99.95%	99.99%
Lead pH 6.5	0.15 mg/L ± 10%	0.010 mg/L		98.50%
Lead pH 8.5	0.15 mg/L ± 10%	0.010 mg/L		99.90%

Note: The manufacturer is required to re-test the product every 5 years for material safety, structural integrity and all performance claims made. Any change to the product must be submitted to the certification agency for a technical review. Testing may be required sooner based on the technical review.

**WARNING:** Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Note: The system must be installed and maintained according to manufacturer's recommendations, including replacement of filter cartridges. The contaminants or other substances removed or reduced by this system are not necessarily in your water. Please see Product Installation manual for details.